

Lead and Copper Consumer Notice Drinking Water Sample Results Table


(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name : Climax-Scotts Elementary

WSSN : 2013539

<u>Sample Number</u>	<u>Sample Location</u>	<u>Sample Date</u>	<u>Analyte Code</u>	<u>Results *</u> milligrams / liter	<u>Comment</u>
<i>Samples related to Source #</i>					
LI41552	KITCHEN SINK W	6/6/2019	Lead	0.001	
LI41552	KITCHEN SINK W	6/6/2019	Copper	0	
LI41553	WC RM 215	6/6/2019	Lead	0	
LI41553	WC RM 215	6/6/2019	Copper	0	
LI41554	WC RM 210	6/6/2019	Lead	0	
LI41554	WC RM 210	6/6/2019	Copper	0.05	
LI41555	WC MUSIC HALL	6/6/2019	Lead	0	
LI41555	WC MUSIC HALL	6/6/2019	Copper	0.07	
LI41556	WC RM 119	6/6/2019	Lead	0	
LI41556	WC RM 119	6/6/2019	Copper	0	



 Douglas P. Newington, Superintendent
 Climax-Scotts Community Schools
 372 South Main Street, Climax, MI 49034
 (269) 746-2400

July 19, 2019

*** All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at www.epa.gov/lead, or contact your health care provider.